

June 25, 1962

Mr. Young
Van Hornsville
New York

Dear Mr. Young:

Our office has run a simple water analysis on the sample you submitted. The results were as follows:

pH 7.1

calcium hardness expressed as calcium carbonate 513
parts per million

total alkalinity expressed as calcium carbonate 140
parts per million

These quantities when plugged into the Langlier Formula show that your fresh water is nearly in balance with a very slight scale forming tendency. It is our suggestion that this condition can be corrected with the addition of approximately 2½ pounds of Calgon water softener per 30,000 gallons of water in your pool. The Calgon can be bought in any local grocery store. The water treatment for your pool for normal operation will be covered in an instruction sheet which will be supplied to you when your pool is put in operation.

Very truly yours,

PADDOCK POOL BUILDERS, INC.

Herb S. Ellis

HSE/sk